

TEST REPORT

CPRI

Date: 19 March 2025

Test Report Number : CPRIBPLSTNC25T0109

Name and Address of the Customer : M/s. E-Techno Switchgear Pvt. Ltd.,
143-A, Sector-H, Govindpura,
Bhopal-462 023.

Name and Address of the Manufacturer : M/s. E-Techno Switchgear Pvt. Ltd.,
143-A, Sector-H, Govindpura,
Bhopal-462 023.

Particulars of sample tested : 33kV/11kV Control and Relay Panel

Type : 11/33kV

Description of test sample : 33kV/11kV Control and Relay Panel

Serial Number : ETS/CRP/24-25/73

Number of samples tested : One

Date(s) of Test(s) : 05 March 2025 & 06 March 2025

CPRI Sample code Number(s) : STNC25S0169

Particulars of tests conducted : Degree of Protection IP-55(Category-II)

Test in accordance with : IEC 60529:2013.

Standard/specification

Sampling Plan : Nil

Customer's Requirement : Nil

Deviations, if any : Nil

Name of the witnessing persons

Customer's representative : 1) Mr. Abhijeet Khavaskar
2) Mr. Ankit Bijalwan.

Other than customer's representative : Nil

Test subcontracted with address of the laboratory : None

Documents constituting this report (in words)

Number of Sheets : Six

Number of Oscillogram(s) : Nil

Number of Graph(s) : Nil

Number of Photograph(s) : Two

Number of Test Circuit Diagram(s) : Nil

Number of Drawing(s) : One



(Manish Kumar Keshari)
Test Engineer




(Sarita Dongre)
Head of Division
Reviewed and Authorized By